


- NOTES:**
1. THIS DETAIL DOES NOT APPLY TO ELECTRICAL CONDUIT INSTALLATION; THIS DETAIL ONLY APPLIES TO LATERAL CONNECTIONS PERPENDICULAR TO THE STREET.
 2. PLACE PERMANENT PAVEMENT WITHIN FIVE (5) DAYS AFTER BACKFILLING AN EXCAVATION. STEEL PLATING IS REQUIRED DURING THE CURING PERIOD OF THE 2 SACK SAND/CEMENT SLURRY BACKFILL, 3 DAYS MIN TO 5 DAYS MAX.
 3. IF EXISTING AC SECTION IS LESS THAN 4" THICK, GRIND AC KEY TO FULL DEPTH OF EX AC AND REPLACE FULL DEPTH AC SECTION (2" MIN).
 4. RECESSED TRENCH PLATES SHALL BE USED AT THE FOLLOWING LOCATIONS: ALL ARTERIAL STREETS, ALL COLLECTOR STREETS, AT TRENCH ALIGNMENTS NOT PARALLEL WITH OR PERPENDICULAR TO THE DIRECTION OF TRAFFIC, AND LOCATIONS DETERMINED BY THE ENGINEER TO BE NECESSARY.
 5. THE CONTRACTOR SHALL PREPARE FOR PLACEMENT OF PLATES OVER TRENCH BY GRINDING A RELIEF 12" WIDE ON EACH SIDE OF THE TRENCH BY THE THICKNESS OF THE STEEL PLATE SO THAT THE SURFACE OF THE STEEL PLATE IS LEVEL WITH THE ADJACENT PAVEMENT SURFACE.
 6. FOR ELECTRICAL TRENCH RESTORATION, REFER TO DETAIL NO. E-15, E-16, OR E-17.



**CITY OF CAMPBELL
PUBLIC WORKS DEPARTMENT**

APPROVED BY: AO DATE: 3/14/22

AMY OLAY, P.E.
CITY ENGINEER

**TRENCH RESTORATION
(LATERAL)**

J:/DETAILS/CAD/C21

**DETAIL NO.
C-21**

NTS