



**NOTES:**

1. FOLLOWING CONDUIT AND SLURRY INSTALLATION UP TO GRADE, EXISTING AC PAVEMENT AND SLURRY TO BE GROUND AND REPLACED WITH PERMANENT AC SURFACE (1 1/2" DEPTH; TYPE A 1/2" MAX, MEDIUM, 95% COMPACTION).
2. EXISTING AC PAVEMENT BETWEEN LIP OF GUTTER AND TRENCH SHALL BE GROUND AND REPLACED WITH KEY.
3. PLACE PERMANENT AC PAVEMENT WITHIN 10 DAYS OF TRENCHING.
4. INSTALL MANUFACTURED CONDUIT CHAIRS BETWEEN CONDUITS IF MORE THAN ONE CONDUIT IS PLACED IN TRENCH.
5. BARRICADING REQUIRED DURING SAND/CEMENT SLURRY CURING PERIOD.



CITY OF CAMPBELL  
PUBLIC WORKS DEPARTMENT

APPROVED BY:

*AO*  
AMY OLAY, P.E.  
CITY ENGINEER

DATE:

3/14/22

SIGNAL, LIGHTING &  
ELECTRICAL CONDUIT  
INSTALLATION - TRENCH LAID  
CONDUIT IN PAVEMENT AREAS

J:/DETAILS/CAD/E15

DETAIL  
NO.

E-15

NTS